

## MARKING OF PANELBOARD DIRECTORIES

**Question:** Would it be acceptable for a load center or panel directory to be marked with a drawing number or print number, rather than in the conventional manner?

**Answer:**

- No this method would not meet the intent of the British Columbia Electrical Code.
- *The Code States - "Provides for quick and easy identification of which switch, circuit breaker, or fuse controls a specific circuit, which may be vital in cases of emergency."*
- Reference Code rule 2-100.