

## **Use of AWM Shielded Cable**

BC Electrical Code Part 1 requires that conductors be of a “type listed in Table 19”. Also, if the conductors are smaller than #14, they must be “equipment wire of the type listed in Table 11”.

Therefore the AWM type conductors may not be installed in installations governed by the requirements of the BC Electrical Code Part 1, except where the cable is supplied as part of an approved assembly to be installed in walls etc. i.e. under floor heating sets. In these cases we would allow the installation of this cable even though it is not listed in Table 11 or 19.